



Bayseal OC Spray-Applied Polyurethane Insulation

PURPOSE: To acknowledge approval of Bayseal OC Spray-Applied Polyurethane Insulation

COMMENTS:

Bayseal OC spray-applied polyurethane insulation is an approved product for use within the Town of Truckee when it is installed in accordance with ICC Evaluation Service Report ESR-1655.

Of particular note, Bayseal OC insulation is not a vapor retarder. Therefore, when the code requires a vapor barrier, one must be installed. If used in an unvented roof assembly, an approved vapor barrier must be used.

Additionally, Bayseal OC insulation must be separated from the interior portion of the building by not less than ½ inch gypsum board or other approved 15 minute thermal barrier.