



Certaspray Foam Insulation

PURPOSE: To acknowledge approval of Certaspray open cell and Certaspray closed cell insulation for use in the Town of Truckee.

COMMENTS:

Certainteed Corporation's Certaspray open cell and closed cell spray foam insulation have been evaluated for use in the Town of Truckee as approved insulation materials. They are found to be acceptable materials when installed in accordance with International Code Council Evaluation Service (ICC-ES) reports ESR-2668 and ESR-2669, respectively for open and closed cell foam.

Both the open and closed cell foams must be applied by certified Certainteed contractors. Both may be installed to a maximum thickness of six inches and must be separated from interior living spaces by an approved thermal barrier of ½ inch thick gypsum wallboard or an equivalent 15 minute thermal barrier.

The open cell foam is not considered a vapor retarder. Therefore, if it is used in an unvented rafter assembly, a vapor barrier with a permeance of one perm or less is required (California Energy Code Sections 101 and 150 (g)).

See the research reports for other conditions of use.