



TOWN OF TRUCKEE
COMMUNITY DEVELOPMENT DEPARTMENT
BUILDING AND SAFETY DIVISION

Sealection500 and Sealection Agribalance Spray Foam Insulations

PURPOSE: To acknowledge approval of Sealection500 and Sealection Agribalance spray foam insulation in the Town

COMMENTS:

Sealection500 and Sealection Agribalance spray applied foam insulations have been evaluated for use in the Town of Truckee as an approved insulation material. They are found to be acceptable material when installed in accordance with International Code Council (ICC) Evaluation Service (ES) reports ESR-1172 (for Sealection500) and ESR-2600 (for Sealection Agribalance) and the manufacturer's installation instructions.

NOTES:

Sealection 500 is not to be installed greater than six inches in thickness (Section 3.2 of ESR report) anywhere, 5 ½ inches between wood joists or rafters, and 3 ½ inches on vertical wall surfaces in crawl spaces and attics. This product is not to be used as fire stopping or draft stopping. No information has been provided regarding vapor transmission. Therefore, use an approved vapor barrier where otherwise required by code. See Section 5.0 of the report for other conditions of use.

Sealection Agribalance is not to be installed greater than ten inches in thickness on the underside of floor or roof sheathing and 7 ½ inches in wall cavities. Thickness shall not exceed 7 ½ inches on vertical wall spaces in attics and crawl spaces and shall be covered with Andek fireguard intumescent coating. A vapor barrier must be installed when required by the code.