



**Expedited Review for Emergency Standby Generators
 For Existing Macro Cell Towers (AB2421)**

Project Address: _____

Assessor's Parcel No.: _____ Date of submittal: _____

Owner/Authorized Agent Name: _____

Owner/Authorized Agent Telephone No: _____

Owner/Authorized Agent Signature: _____

To qualify for Expedited Review, all AB2421 qualifying criteria must be met. The applicant shall initial next to each of the criteria below and provide supporting documentation as part of the permit submittal. The applicant shall indicate the submittal of an "Expedited Review - AB2421 permit request" in the subject line when submitting the plans to CDD@TownofTruckee.gov.

1. The emergency standby generator is rated below 50 horsepower, compliant with applicable air quality regulations, has a double-wall storage tank, not to exceed 300 gallons, and is mounted on a concrete pad.	
2. The macro cell tower site at which the emergency standby generator is proposed to be installed is an existing site that was previously permitted by the applicable local agency.	
3. The emergency standby generator complies with all applicable state and local laws and regulations, including building and fire safety codes.	
3. A site plan has been submitted, showing all existing and proposed structures on the property. The site plan must be to scale and must include site coverage calculations.	
4. The physical dimensions of the emergency standby generator and storage tank are cumulatively no more than 250 cubic feet in volume.	
5. The emergency standby generator shall be located not more than 100 feet from the physical structure of the macro cell tower or base station.	